

## **ENERGY AUDIT REPORT**





## Detached House - 1970 - Cavity wall construction - 239m² (2564ft²)




Barna,	County	Ga	lway
--------	--------	----	------

Existing Building Details				
Building Elements		Insulation Thickness (mm)	U-Value (W/m².K)	
Walls	320mm Cavity Wall Insulated	100mm-150mm	0.35	
Roof	Pitched Roof insulated at ceiling	50mm-100mm	0.68	
Floor	Solid Floor	Unknown	0.61	
Windows	Double Glazed Air filled	N/A	2.7-3.1	
Doors	Glazed Door	N/A	3	

Existing Heating Characteristics			
	Heating System	Energy	Efficiency (%)
Primary Heating System	Oil boiler, primary pipework uninsulated	Oil	65%-70%
Secondary Heating System	Stoves	Multi fuel	70%
Domestic Hot Water	Heated with Oil Boiler & Electric immersion		
Cylinder	Factory cylinder Insulated (30mm)		
Controls	Timer, No TRV		

Domestic Retrofit Guidelines (Step by Step)			Energy Consumption (kWh/m²/yr)	Carbon Emissions (CO2) (kgCO2/m²/yr)	Building Energy Rating (BER)	
	Energy Efficient Measures		Target U-Value (W/m2.K)	Current Usage (231.68)	Current Emissions (56.99)	Current BER (D1)
1	Roof insulation	Loftwool Insulation top-up to achieve 300mm- 400mm across all roof area.	0.13 - 0.16	200.12	48.95	СЗ
2	External/Internal Wall Insulation	Install Wall Insulation (internal or External), thickness 50mm-100mm	0.18 - 0.21	181.49	44.19	C2
3	Floor Upgrade	Insulate solid floor with rigid insulation	0.15 - 0.18	156.71	37.88	C1
4	Window/Door Upgrade	Replace existing glazing with Double/Triple glazed,(low E) units	1.1 - 1.4	145.54	35	В3
5	Lighting	Install energy efficient light bulbs (LEDs)	N/A	139.69	34.08	В3
6	Heating Upgrade (Primary)	Air to water heat pump, 10-12kW, two separate heating zones and controller.	N/A	81.89	17.26	B1
7	Renewables	Install 2.4 kWp Solar PV system	N/A	71.56	15.09	А3
8						
9						
10						






## **ENERGY AUDIT REPORT**







	Estimated Costs Summary				
	Measures	Estimated Costs (€/m²)	Estimated Total Costs (€)		
1	Roof Upgrade	10 - 15	€ 2,252		
2	Wall Insulation	70-100	€ 14,342		
3	Floor Upgrade	80 - 100	€ 21,431		
4	Window/Door upgrade	250 - 350	€ 15,733		
5	Lighting	20/fitting	€ 400		
6	Heating Upgrade (Primary)	12,500 (System)	€ 12,500		
7	Solar PV	4,400 (2.4 kWp System)	€ 4,400		
8	Demand Controlled Ventilation	3,000 (System)	€ 3,000		
9	0	0	€ 0		
10	0	0	€ 0		
	Total	€ 74,058			
	Total Cost to Homeowner including 35% Grant funding	€ 48,138			

Savings Summary				
BER Rating	Energy Savings (kWh/m²/yr)	Energy Savings (kWh/yr)	Cost Savings (€/yr)	Simple Payback, including 35% Grant Funding (years)
A3	160.12	38,128	€ 1,906	25

Audit site visit completed on 14/11/2019, Audit report edited on 10/12/2019



(a) +353 (0) 56779 0856 admin@3cea.ie www.3cea.ie